



Proposed Code Change

State Form 41186R

RETURN TO:
INDIANA DEPARTMENT OF HOMELAND SECURITY
CODE SERVICES SECTION
302 W. Washington Street Room W246
Indianapolis, IN 46204

FOR OFFICE USE ONLY

Received 3/15/10

Code 50.7.5-09

INSTRUCTIONS:

Only TYPED copy accepted.

(KEY – ~~Dashed line through material to be deleted~~, underline material to be added)

Use second sheet for any material requiring more space.

Code Title International Residential Code		Edition 2009
Section number and title R502.11.2 Bracing		Page 121
Proponent William Fox / IBA	Title Code Committee Member	
Address 6125 W 29 th Place, Speedway, IN. 46224		Phone 317-291-7575
PROPOSED CODE CHANGE (Check One)		
<input type="checkbox"/> Change to read as follows <input type="checkbox"/> Add to read as follows <input type="checkbox"/> Delete and substitute as follows <input checked="" type="checkbox"/> Delete without substitution		
<p>Delete without substitution the last line of Section R502.11.2 Bracing. Trusses shall be braced to prevent rotation and provide lateral stability in accordance with the requirements specified in the construction documents for the building and on the individual truss design drawings. In the absence of specific bracing requirements, trusses shall be braced in accordance with the Building Component Safety Information (BCSI 1-03) Guide to Good Practice for Handling, Installing & Bracing of Metal Plate Connected Wood Trusses.</p>		
REASON AND FISCAL IMPACT		
<p>As written this is a liability for builders and building officials. Deleting this option rightfully places the liability on the truss manufacturer.</p>		
REVIEW RECOMMENDATION		
Approve		
Disapprove 12-7-0 3/16/10		
Approve as amended		
Further Study		